

# **TRIOS-21 MICRO CLEAN**

## **MICROBIOLOGICAL MEMBRANE CLEANER**

Reverse Osmosis systems are clogged over time due to the accumulation of water. Timing of cleaning process should be well performed in clogged membranes. Cleaning should not be performed before or after its due time. The most appropriate time for membrane cleaning is when the recovery efficiency decreases by 15% or the pressure difference increases by 15%. Acidic, alkaline and microbiological cleaning should be performed according to the cause of membrane obstruction. Our membrane cleaners and antiscalate products are compatible with Reverse Osmos (RO), nanofiltration (NF), ultrafiltration (VF) and microfiltration (MA) systems.

It is used for cleaning microbiological contaminations such as bacteria, viruses, algae, etc.

### **DOSAGE AMOUNT AND INTENDED USE**

The 5% solution of TRIOS-21 MICRO CLEAN should be circulated for 1-2 hours. After cleaning, rinse with water.

**NOTE: Please review the MSDS reports before use for safety, occupational health and safety.**